

Confirmation

LEED

On 28 March 2014 and on 03 July 2008, Eurofins Product Testing A/S received samples of a coating with the product name:

PU Siegel / PU Sealer / Waxnomor

supplied by

cc – Dr. Schutz GmbH

The samples were supplied as being representative of the manufactured product, and they have been tested as coating in accordance with the relevant ISO 16000, ISO 11890-1, and ASTM D2369 and EPA method 24 testing standards (See the test reports no. 392-2014-00052701rev3 and 765595).

The test results of the tested coating indicate that the product qualifies for LEED 2009 and LEED v4 specifications on VOC emissions and/or VOC content by complying with:

VOC emissions specifications in LEED EQ credit "Low-emitting products":

- the requirements of DIBt (October 2010) and AgBB (June 2012), and the formaldehyde limit of 10 µg/m³ after 28 days.

VOC content specifications in LEED EQ credit "Low-emitting products":

- the requirements of CARB SCM 2007,
- the requirements of SCAQMD rule 1113 (2011).

18 July 2014



Søren Ryom Villadsen
Analytical Service Manager