



DEUTSCHES
AKKREDITIERUNGSSYSTEM
PRÜFWESSEN GMBH **DAP**
Durch die Deutsches Akkreditierungssystem Prüfwesen GmbH
nach DIN EN ISO/EC 17025 akkreditiertes Prüflaboratorium
DAP-PL-1033.00



Entwicklungs- und Prüflabor
Holztechnologie GmbH

Entwicklungs- und Prüflabor Holztechnologie GmbH · Zellescher Weg 24 · 01217 Dresden

CC-Dr. Schutz GmbH
Herrn Jörg Dröge
Steinbrinksweg 30

31840 Hessisch Oldendorf

Zellescher Weg 24
01217 Dresden · Germany

Telefon +49 (0) 351/4662-0
Telefax +49 (0) 351/4662-211

E-mail eph@ihd-dresden.de
Internet www.eph-dresden.de

Dresden, 23 July 2010
70-em/klö

Test report Order-No. 270055

Customer: CC-Dr. Schutz GmbH
Steinbrinksweg 30
31840 Hessisch Oldendorf

Date of order: 10.02.2010

Order: Testing of the resistance against cold liquids

Auftragnehmer: EPH – Laboratory Surface Testing

Engineer in charge: Dipl.-Ing. (FH) M. Hanitzsch

Dr.-Ing. R. Emmeler
Head of Laboratory Surface Testing

The test report contains 2 pages. Every duplication in part requires a permit of EPH. The test results are only related to the tested material.

1 Task

The authorized laboratory Entwicklungs- und Prüflabor für Holztechnologie GmbH (EPH) was commissioned by CC-Dr. Schutz GmbH in 31840 Hessisch Oldendorf to carry out testing the resistance against cold liquids of two PVC-floorings.

2 Test material

The customer has sent two variants of PVC-design-flags, dimension 300 x 300 x 2.5 mm. Receipt at the EPH-laboratory: 15.02.2010. The variants were identified from the customer as following:

Var. 1: PU Anticolor
Var. 2: PU seal matt

3 Determination of the resistance against cold liquids

The determination of the resistance against cold liquids was carried out according to DIN 68861 part 1 / EN 12720, level of use 1B.

4 Results

variant	Test result DIN 68861 part 1, level of use 1B
1	Level of use 1B fulfilled for all tested agents
2	Level of use 1B fulfilled for all tested agents

5 Evaluation

The two coated PVC-design-flags (var. 1 and 2) fulfil the requirements of the level of use 1B according to DIN 68861 part 1.


Dipl.-Ing. (FH) M. Hanitzsch
verantwortlicher Bearbeiter